


0107016-00431



Architecture | Engineering | Planning

1200 R Street, Suite 100
Sacramento, CA 95811
(916) 784-5100 fax (916) 784-7738

APPROVED PLAN

SEP 30 2016
BY 
SAN MATEO COUNTY BUILDING
INSPECTION DIVISION

**San Mateo County Department of Public Works and
Health System Behavioral Health and Recovery
Services**

Serenity House

**JOB COPY
TO REMAIN ON
SITE AT ALL TIMES**

Structural Calculations



REVISION

SEP 06 2016

**San Mateo County
Building Inspection**

Commission No: 3505-003-01
Serenity House – County of San Mateo
Date: August 26, 2016



SI 25

Floor loads

Finish	1
Sheathing	2
Framing	4
MEP	2
Ceiling	4
Partitions	15

28 psf → Say 30 psfLive = 40 psfMaterials:

DFL No. 1 & Better

-(JOISTS)

$$F_b = 1,200 \text{ psi}$$

$$E = 1,800,000 \text{ psi}$$

$$F_v = 180 \text{ psi}$$

$$E_{min} = 660,000 \text{ psi}$$

$$C_m = 1.0$$

$$C_F = 1.3 \text{ (2x6)}$$

$$C_D = 1.0$$

$$C_E = 1.0$$

$$C_L = 0.95$$

$$F_b^* = 1200 \times (1.3) \times (1.15) = 1794 \text{ psi}$$

$$C_{Fu} = 1.0$$

$$C_i = 1.0$$

$$C_r = 1.15 \text{ (Joist)}$$

$$F_b' = 1794 \times 0.95 = \underline{\underline{1704 \text{ psi}}}$$

$$F_v' = 180 \times (1.0)^4 = \underline{\underline{180 \text{ psi}}}$$

Materials

DFL No. 1 & Better - (HEADER)

$$F_b = 1200$$

$$E = 1800000 \text{ psi}$$

$$F_y = 180$$

$$E_{min} = 660000 \text{ psi}$$

$$C_m = 1.0$$

$$C_F = 1.3 \quad (4 \times 6 \text{ or } 8)$$

$$C_D = 1.0$$

$$C_E = 1.0$$

$$C_L = 1.0$$

$$F_b^* = 1200 \times 1.3 = \underline{1560 \text{ psi}}$$

$$C_{FU} = 1.0$$

$$C_r = 1.0$$

$$F_b' = \underline{\underline{1560 \text{ psi}}}$$

$$F_v' = \underline{\underline{180 \text{ psi}}}$$

USGS Design Maps Summary Report

User-Specified Input


Report Title San Mateo Serenity House
 Mon November 9, 2015 15:45:23 UTC

Building Code Reference Document ASCE 7-10 Standard
 (which utilizes USGS hazard data available in 2008)

Site Coordinates 37.531°N, 122.302°W

Site Soil Classification Site Class D - "Stiff Soil"


Risk Category I/II/III



USGS-Provided Output

$S_s = 2.012 \text{ g}$	$S_{MS} = 2.012 \text{ g}$	$S_{DS} = 1.341 \text{ g}$
$S_1 = 0.948 \text{ g}$	$S_{M1} = 1.421 \text{ g}$	$S_{D1} = 0.948 \text{ g}$

For information on how the S_s and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



For PGA_M , T_L , C_{RS} , and C_{R1} values, please [view the detailed report](#).

54 of 25

Check new floor spans 8'-0" Span

$$W = (30 + 40) \times 1.33' = \underline{93 \text{ plf}}$$

$$M = \frac{93 (8)^2}{8} = \underline{744 \text{ lb}\cdot\text{ft}}$$

$$S_r = \frac{744 \times 12}{1704} = \underline{5.24 \text{ in}^3}$$

$$A_r = \frac{[93 \times 8/2] \times 1.5}{180 \text{ psi}} = \underline{3.10 \text{ in}^2}$$

$$I_r = \frac{5 (93) 8^4 (1728)}{384 (1800 \text{ psi}) 0.40} = \underline{11.9 \text{ in}^4} \quad \begin{array}{l} \ell/480 = 0.20'' \\ \ell/240 = 0.40'' \end{array}$$

$$I_r = \frac{5 (93) 8^4 (1728)}{384 (1800 \text{ psi}) 0.20} = \underline{13.6 \text{ in}^4} \quad \leftarrow \text{Controls}$$

2x6

$$S_x = 7.56 \text{ in}^3 > 5.24$$

$$I_x = 20.60 \text{ in}^4 > 13.6$$

$$A = 8.25 \text{ in}^2 > 3.10$$

All ok - Use 2x6
at 16" o.c.

New Header - Near Lift

$$\text{Trib} = 4'-3" \text{ max} , \quad \text{Span} = 6'-0" \text{ max}$$

$$W = (30 + 40) \times 4.25' = \underline{298 \text{ plf}}$$

$$W_L = \underline{170 \text{ plf}}$$

$$M = (298) (6)^2 / 8 = \underline{1341 \text{ ft}\cdot\text{lbs}}$$

$$V = 298 \times 6 / 2 = \underline{894 \text{ lbs}}$$

Try Sawn Lumber

$$L/360 = 0.20" \quad L/240 = 0.30"$$

$$I_r = \frac{5 (170) 6^4 (1728)}{384 (1800000) 0.20} = \underline{13.8 \text{ in}^4}$$

$$I_r = \frac{5 (298) 6^4 (1728)}{384 (1800000) 0.30} = \underline{16.1 \text{ in}^4} \leftarrow \text{Controls}$$

$$S_r = \frac{1341 \times 12}{1500} = \underline{10.3 \text{ in}^3}$$

$$A_r = \frac{894 \times 1.5}{180} = \underline{7.45 \text{ in}^2}$$


Use 4x6

$$A = 19.25 \text{ in}^2$$

$$S_x = 17.05 \text{ in}^3$$

$$I_x = 48.53 \text{ in}^4$$

Sl of 25

BEAM AT FIRST FLOOR w/LIFT SUPPORT POSTS


$$W = (30 + 40) \times 1.0 = \underline{\underline{70 \text{ pif}}}$$

$$\delta_{lim} = l/240 = \underline{\underline{0.86''}}$$

$$\text{Live } \delta = e/480 = \underline{\underline{0.43''}}$$

From RISA

$$M = 7815 \text{ lb}\cdot\text{ft}$$

$$R = 1638 \text{ lbs}$$

$$V = 1638 \text{ lbs}$$

EQ w

$$w = \frac{8(7815)}{(17.167)^2} = 212 \text{ pif}$$

$$\delta = \frac{270(212)(17.167)^4}{[2.0 \times 10^6] 3.5 (11.875)^2} + \frac{28.8(212)(17.167)^2}{[2.0 \times 10^6] (3.5)(11.875)} = \underline{\underline{0.44''}}$$

Total Load ✓

- Use 3.5 x 11.875 LVL on one side

Check Bi-axial case w/Lift - 5.25 x 11.875 LVL

$$M_z = 6721 \text{ lb}\cdot\text{ft}$$

$$M_{az} = 29,900 \text{ lb}\cdot\text{ft}$$

$$M_y = 2819 \text{ lb}\cdot\text{ft}$$

$$M_{ay} = \frac{3430 \times 54.55}{12} = \underline{\underline{15592 \text{ lb}\cdot\text{ft}}}$$

$$S_y = \frac{11.875 \times (5.25)^3}{12} = 54.55$$

$$\frac{6721}{29900} + \frac{2819}{15592} = \underline{\underline{0.41 \leq 1.0}}$$

12' High Fence Post

Wind = 16 psf (ASD)

6' Trib

$$W = 16 \text{ psf} \times 6' = 96 \text{ plf}$$

$$S_{lim} = 2d/120 = d/60 \quad 144/60 = 2.4''$$

$$I_r = \frac{(0.096)(12)^4 1728}{8 (29000) 2.4''} = \underline{\underline{6.912 \text{ in}^4}}$$

$$M_u = 1.67 (0.096) (12)^2 / 2 = 11.54 \text{ k.ft}$$

$$Z_r = \frac{11.54 \times 12}{0.9 (26)} = \underline{\underline{3.34 \text{ in}^3}}$$

HSS 5x2x1/4

$$I_x = 8.08 \text{ in}^4 \checkmark$$

$$Z_x = 4.27 \text{ in}^3 \checkmark$$

$$S_x = 3.23 \text{ in}^3 \checkmark$$

Beam TB

$$OTM M_u = 1.67 (0.096 \times 12) \times 6' = \underline{\underline{11.54 \text{ k.ft}}}$$

Try 6x9 1/2" Long

1/2 Conc. Bearing length.

$$C = (2.2 \text{ ksi}) (6y) = 13.2y$$

$$M_u = 11.54 \times 12 = 138.48 \text{ k.in}$$

$$\text{Arm} = 8.5'' - 1/2''$$

Solve for y

$$6.6y^2 - 112.2y + 138.48 = 0$$

$$y = 1.33''$$

$$C = 13.2 (1.33) = 17.69 \text{ k}$$

$$T = C$$

bolt

$$N_u = T/2 = 17.69/2 = \underline{\underline{8.84 \text{ k/bolt}}}$$

$$A_r = \frac{8.84}{0.75 (45 \text{ ksi})} = 0.264 \text{ in}^2 \quad \therefore \text{Use } 5/8$$

$$A_g = \underline{\underline{0.307 \text{ in}^2}} \checkmark$$

A307

Beam TE Cont'd

Irreg. - tension

$$\text{bending Arm} = 3.5'' - 2.5'' = 1''$$

$$T = 17.69 \text{ k}$$

$$M_u = 17.69 \times 1'' / 6'' \text{ wide TE} = \underline{\underline{2.94 \text{ k-in/in}}}$$

$$t_r = \sqrt{\frac{4(2.94)}{0.9(36 \text{ ksi})}} = \underline{\underline{0.602''}}$$

t_{ry} - Beam-g

$$\text{Arm} = 2'' - 1/2'' = 2 - 1.33/2 = 1.34''$$

$$M_u = 17.69 \times 1.34 / 6'' = 3.936 \text{ k-in/in}$$

$$t_r = \sqrt{\frac{4(3.936)}{0.9(36 \text{ ksi})}} = \underline{\underline{0.697''}}$$

Use 5/8" TE

TE 5/8" x 6" x 0'-9 1/2"

w/ 5/8" ϕ A307 Anchor Bolts

Weld Tube to TE


$$M_u = 11.54 \times 12 = 138.43 \text{ k-in} \quad V_u = 1.92 \text{ k}$$

$$\sum l_w = 2(1'') + 2(3.5'') = 9''$$

$$S_w = \frac{3.5^2}{3} + (1 \cdot 5) = 9.08 \text{ in}^2$$

$$r_u = \frac{1.92}{9''} + \frac{138.43}{9.08} = \underline{\underline{15.4 \text{ k/in}}} \text{ Very large}$$

- Use 2x2 TE stiffens w/ 5/16 fillets



Pier 14" x 18"

$$A_r = 0.01 (14 \times 18) = 2.52 \text{ in}^2$$

Use #8 bars

$$4 (0.79) = 3.16 \text{ in}^2$$

Bending

$$A_s = 2 (0.79) = 1.58$$

$$d = 12.5''$$

$$\phi M_n = 0.7 \left[\frac{60 (1.58) (12.5 - \frac{60 (1.58)}{2 (0.55) 4 (14)})}{12} \right] = 81.8 \text{ k.ft}$$

$$M_u = 11.54 \text{ k.ft} + 1.67 (0.096 \times 12) \times 4.5' = 20.2 \text{ k.ft} \leq \phi M_n$$

-ok ✓

$$l_{dn} = \left[\frac{0.02 (60,000)}{1.0 \sqrt{4000}} \right] 1.0'' = 18.97''$$

$$18.97 \times 0.7 = \underline{\underline{13.3''}} \checkmark$$

SW of 25

Conc Pier Under Fence Post

18" x 14"

$$A_{sp} = 18 \times 14 \times 0.01 = 2.52 \text{ in}^2$$

4-#7

 A little light,
 $A_s = 2.40$ - Say ok

 $\phi M_n =$

$$d = 18" - [2" + 0.375 + 0.5"] = 15"$$

$$A_s = 0.60 \times 2 = 1.20 \text{ in}^2$$

$$\phi M_n = 0.9 \left[60(1.20) \left(15" - \frac{60(1.20)}{2(0.85)4(14")} \right) \right] = \underline{\underline{76.9 \text{ k}\cdot\text{ft}}}$$

12

$$M_u = 11.54 \text{ k}\cdot\text{ft} + [1.67(0.096)12'] \times 4' = \underline{\underline{19.24 \text{ k}\cdot\text{ft}}} \leq 76.9 \text{ ✓ok}$$

↑
from Post
Calc

$$V_u = 1.67(0.096) \times 12 = \underline{\underline{1.92 \text{ k}}}$$

 ϕV_u - ok by inspection ✓

l_{dh} #7

$$l_{dh} = \left[\frac{0.02(1.0)60,000}{1.0\sqrt{4000}} \right] 0.875" = 16.6"$$

$$l_{dh} = 0.70 \times 16.6 = 11.62" \text{ Say } 12" \text{ ✓ok}$$

↑
2" +
cover

RETAINING WALL DESIGN

PROJECT-
TITLE-


H(K)= 0 TOP OF
P(K)= 0 WALL
M(K-FT)= 0 FORCES

STATIC CASE


INPUT VALUES		CALC VALUES		RESIST FORCES			SOIL	PRESS
GAM(pcf)=	100	EQ FL=	44.0	P(KIP)	X(FT)	PX	Mt(K-FT)=	19.115
SUR(psf)=	40			BACKFILL	4.14	4.29	E(FT)=	0.528
Ka=	0.44	M-OT=	4.32	STEM	0.68	1.00	L6=	1.208
Kp=	1	F-SL=	1.55	FILL	0.07	0.33	3(L/2-E)=	0.000
μ=	0.35			FOOT	1.05	3.63	P-MAX=	0.000
H(ft)=	8	M-add=	0.00	SURCH	0.24	4.29	P-1=	1.224
H'(ft)=	2	F-add=	0.00				P-2=	0.479
T-STEM(in)	8				6.17	3.77		
T-BASE(in)	12	M-tot=	4.32			23.30		
W(ft)=	7.25	F-tot=	1.55	F-RES,U=	2.16	M-RES,G=	23.30	P-CODE=TOE
B(ft)=	0.67			F-RES,P=	0.20	M-RES,P=	0.13	
*C(ft)=	5.92			SUM=	2.36	SUM=	23.43	F(NET)=
Fc(psi)=	4000							1.35
Fy(ksi)=	60							
				SF-SL=	1.52	SF-OT=	5.43	

CONCRETE DESIGN

STEM							FTG	
h	t	Mu	p	Ph-Vc	V/Vc	As	HEEL	
0.00	8	5.0	.00315	7.1	0.29	0.21	D-HEEL=	9.5
0.70	8	3.7	.00232	7.1	0.24	0.17	LF-SOIL=	0.9
1.40	8	2.7	.00165	7.1	0.19	0.17	VU-FILL=	7.49
2.10	8	1.8	.00113	7.1	0.15	0.17	VU-SOIL=	4.37
2.80	8	1.2	.00073	7.1	0.11	0.17	VU-NET=	3.11
3.50	8	0.7	.00044	7.1	0.08	0.17	OK PHI*VC=	12.26
4.20	8	0.4	.00024	7.1	0.05	0.17	MU-FILL=	23.31
4.90	8	0.2	.00011	7.1	0.03	0.17	MU-SOIL=	11.63
5.60	8	0.1	.00004	7.1	0.02	0.17	MU-NET=	11.68
6.30	8	0.0	.00001	7.1	0.01	0.17	p=	.00245
7.00	8	0.0	.00000	7.1	0.00	0.17	AS=	0.28
							AS(MIN)=	0.26



OK PHI*VC=	10.97
MU=	0.45
p=	.00012
AS=	0.01
AS(MIN)=	0.26
TOE	
D-TOE=	8.5
VU=	-0.09
OK PHI*VC=	10.97
MU=	0.45
p=	.00012
AS=	0.01
AS(MIN)=	0.26
LONGIT TEMP STEEL	
AS=	1.88



HGA

RETAINING WALL DESIGN

PROJECT-TITLE:

H(K)= 0.264
 P(K)= 0.7
 M(K-FT)= 1.45

FENCE LOADS
 TOP OF WALL FORCES


S12 of 25

INPUT VALUES				CALC VALUES				RESIST FORCES			SOIL PRESS	
GAM(pcf)=	100	EQ FL=	44.0			P(KIP)	X(FT)	PX	Mt(K-FT)=	15.801		
SUR(psf)=	0			BACKFILL	4.14	4.29	17.77		E(FT)=	1.244		
Ka=	0.44	M-OT=	3.75	STEM	1.38	1.00	1.38		L/6=	1.208		
Kp=	1	F-SL=	1.41	FILL	0.07	0.33	0.02		3(L/2-E)=	7.143		
μ=	0.35			FOOT	1.05	3.63	3.81		P-MAX=	1.858		
H(ft)=	8	M-add=	3.56	SURCH	0.00	4.29	0.00		P-1=	0.000		
H'(ft)=	2	F-add=	0.26						P-2=	0.000		
T-STEM(in)	8				6.64	3.46	22.98					
T-BASE(in)	12	M-tot=	7.32						P-CODE=	TOE		
W(ft)=	7.25	F-tot=	1.67	F-RES,U=	2.32	M-RES,G=	22.98					
B(ft)=	0.67			F-RES,P=	0.20	M-RES,P=	0.13					
*C(ft)=	5.92			SUM=	2.52	SUM=	23.12		F(NET)=	1.47		
Fc(psi)=	4000											
Fy(ksi)=	60											
				SF-SL=	1.51	SF-OT=	3.16					

CONCRETE DESIGN

STEM							FTG	
h	t	Mu	p	Phi-Vc	V/Mc	As	HEEL	
0.00	8	9.9	.00641	7.1	0.32	0.42	D-HEEL=	9.5
0.70	8	8.4	.00541	7.1	0.27	0.36	LF-SOIL=	0.9
1.40	8	7.2	.00457	7.1	0.23	0.30	VU-FILL=	7.08
2.10	8	6.1	.00389	7.1	0.19	0.26	VU-SOIL=	4.24
2.80	8	5.3	.00333	7.1	0.16	0.22	VU-NET=	2.85
3.50	8	4.6	.00287	7.1	0.13	0.19	OK PHI*VC=	12.26
4.20	8	4.0	.00250	7.1	0.10	0.17	MU-FILL=	22.03
4.90	8	3.5	.00220	7.1	0.09	0.17	MU-SOIL=	8.50
5.60	8	3.1	.00195	7.1	0.07	0.17	MU-NET=	13.53
6.30	8	2.8	.00173	7.1	0.07	0.17	p=	.00285
7.00	8	2.5	.00153	7.1	0.06	0.17	AS=	0.32
							AS(MIN)=	0.26
							TOE	
							D-TOE=	8.5
							VU=	-0.13
							OK PHI*VC=	10.97
							MU=	0.68
							p=	.00017
							AS=	0.02
							AS(MIN)=	0.26
							LONGIT TEMP STEEL	
							AS=	1.88

OMIT 8/26/16



HGA

RETAINING WALL DESIGN

PROJECT-TITLE:

H(K)= 0
 P(K)= 0
 M(K-FT)= 0

TOP OF WALL FORCES

STATIC CASE

INPUT VALUES		CALC VALUES		RESIST FORCES			SOIL PRESS	
GAM(pcf)=	100	EQ FL=	44.0	P(KIP)	X(FT)	PX	Mt(K-FT)=	8.927
SUR(psf)=	40			BACKFILL	2.43	3.54	E(FT)=	0.416
Ka=	0.44	M-OT=	2.39	STEM	0.53	1.00	L/6=	0.958
Kp=	1	F-SL=	1.04	FILL	0.07	0.33	3(L/2-E)=	0.000
μ=	0.35			FOOT	0.83	2.88	P-MAX=	0.000
H(ft)=	6.5	M-add=	0.00	SURCH	0.18	3.54	P-1=	1.007
H'(ft)=	2	F-add=	0.00				P-2=	0.397
T-STEM(in)	8				4.04	3.02		
T-BASE(in)	12	M-tot=	2.39			12.18	P-CODE=	TOE
W(ft)=	5.75	F-tot=	1.04	F-RES,U=	1.41	M-RES,G=		
B(ft)=	0.67			F-RES,P=	0.20	M-RES,P=		
*C(ft)=	4.42			SUM=	1.61	SUM=		
Fc(psi)=	4000					12.31	F(NET)=	0.84
Fy(ksi)=	60							


SF-SL= 1.55 SF-OT= 5.16

CONCRETE DESIGN

STEM		CONCRETE DESIGN				
h	t	Mu	p	Phi-Vc	V/Vc	As
0.00	8	2.5	.00157	7.1	0.18	0.17
0.55	8	1.9	.00116	7.1	0.15	0.17
1.10	8	1.4	.00083	7.1	0.12	0.17
1.65	8	0.9	.00057	7.1	0.09	0.17
2.20	8	0.6	.00038	7.1	0.07	0.17
2.75	8	0.4	.00023	7.1	0.05	0.17
3.30	8	0.2	.00013	7.1	0.03	0.17
3.85	8	0.1	.00006	7.1	0.02	0.17
4.40	8	0.0	.00002	7.1	0.01	0.17
4.95	8	0.0	.00000	7.1	0.00	0.17
5.50	8	0.0	.00000	7.1	0.00	0.17

Include Passive ?
 N
 Omit
 8/26/16

FTG	
HEEL	
D-HEEL=	9.5
LF-SOIL=	0.9
VU-FILL=	4.67
VU-SOIL=	2.67
VU-NET=	2.00
OK PHI*VC=	12.26
MU-FILL=	10.99
MU-SOIL=	5.40
MU-NET=	5.59
p=	.00116
AS=	0.13
AS(MIN)=	0.26
TOE	
D-TOE=	8.5
VU=	-0.07
OK PHI*VC=	10.97
MU=	0.37
p=	.00010
AS=	0.01
AS(MIN)=	0.26
LONGIT	TEMP
AS=	STEEL
	1.49



HGA

RETAINING WALL DESIGN

PROJECT-
TITLE-

H(K)= 0.264
P(K)= 0.7
M(K-FT)= 1.45

TOP OF WALL FORCES


SK of 25

INPUT VALUES		CALC VALUES		RESIST FORCES			SOIL PRESS	
GAM(pcf)=	100	EQ FL=	44.0	P(KIP)	X(FT)	PX	Mt(K-FT)= 7.208	
SUR(psf)=	0			BACKFILL	2.43	3.54	8.60	E(FT)= 1.295
Ka=	0.44	M-OT=	2.01	STEM	1.23	1.00	1.23	L/6= 0.958
Kp=	1	F-SL=	0.93	FILL	0.07	0.33	0.02	3(L/2-E)= 4.741
μ=	0.35			FOOT	0.83	2.88	2.40	P-MAX= 1.924
H(ft)=	6.5	M-add=	3.17	SURCH	0.00	3.54	0.00	P-1= 0.000
H'(ft)=	2	F-add=	0.26					P-2= 0.000
T-STEM(in)	8				4.56	2.69	12.25	
T-BASE(in)	12	M-tot=	5.18					F-CODE= TOE
W(ft)=	5.75	F-tot=	1.19	F-RES,U=	1.60	M-RES,G=	12.25	
B(ft)=	0.67			F-RES,P=	0.20	M-RES,P=	0.13	
*C(ft)=	4.42			SUM=	1.80	SUM=	12.39	F(NET)= 0.99
Fc(psi)=	4000							
Fy(ksi)=	60							
				SF-SL=	1.51	SF-OT=	2.39	


CONCRETE DESIGN

STEM							FTG	
h	t	Mu	p	Phi-Vc	V/Vc	As	HEEL	
0.00	8	7.0	.00447	7.1	0.22	0.29	D-HEEL=	9.5
0.55	8	6.2	.00393	7.1	0.19	0.26	LF-SOIL=	0.9
1.10	8	5.5	.00347	7.1	0.17	0.23	VU-FILL=	4.37
1.65	8	4.9	.00309	7.1	0.14	0.20	VU-SOIL=	2.39
2.20	8	4.4	.00276	7.1	0.12	0.18	VU-NET=	1.98
2.75	8	4.0	.00248	7.1	0.10	0.17	OK PHI*VC=	12.26
3.30	8	3.6	.00224	7.1	0.09	0.17	MU-FILL=	10.26
3.85	8	3.3	.00203	7.1	0.08	0.17	MU-SOIL=	2.88
4.40	8	3.0	.00185	7.1	0.07	0.17	MU-NET=	7.39
4.95	8	2.7	.00169	7.1	0.06	0.17	p=	.00154
5.50	8	2.5	.00153	7.1	0.06	0.17	AS=	0.18
							AS(MIN)=	0.26
							TOE	
							D-TOE=	8.5
							VU=	-0.14
							OK PHI*VC=	10.97
							MU=	0.69
							p=	.00018
							AS=	0.02
							AS(MIN)=	0.26
							LONGIT	TEMP
							STEEL	
							AS=	1.49

Include Passive ?
N
OMN
8/26/16



HGA



Resultant = $\frac{1}{2} (330) 7.5 = 238 \text{ lbs}$

Arm = $7.5/3 = 2.5'$

Surcharge = 40 psf

$K_a = 0.35$

$W_s = 40 \times 0.35 = 14 \text{ psf}$

8/26/16

~~MIT~~

$M_u = 1.6 (1.24 \times 2.5 + 0.04(7.5)^2/2) = 5.66 \text{ k-ft/ft}$

$V_u = 1.6 (1.24 + 7.5(0.014)) = 2.15 \text{ k/ft}$

8" stem

$A_{s_{min}} = 0.0015 (8 \times 12) = 0.144 \text{ in}^2$


$A_{s_{min}} = 0.0020 (8 \times 12) = 0.192 \text{ in}^2 \leftarrow \#4 @ 12" \text{ o.c.}$

~~#5 @ 10" o.c.~~ $A_s = 0.372 \quad d = 4"$

$\phi M_n = 0.9 \left[60 (0.372) (4" - \frac{60(0.372)}{2(0.85) + (12")}) \right] = 6.24 \text{ k-ft/ft} \checkmark$

- Use #5 @ 10" o.c.

$\phi V_n = \frac{0.75 (2) \sqrt{f_{cs}} (4) (12)}{1000} = 4.55 \text{ k/ft} \geq 2.15 \text{ k/ft}$



$$A_{smin} = 0.0018 (18 \times 12) = 0.39 \text{ in}^2 / \text{ft}$$

$$d = 18 - (3 + 0.5) = 14.5 \text{ in}$$

Say 14"

$$M_{umax} = \frac{1.6 (0.730) 3.63^2}{2} = 8.58 \text{ k-ft/ft}$$

$$V_{umax} = 1.6 (0.730) \times 3.63 = 4.18 \text{ k/ft}$$

#4 @ 12" T $\frac{1}{2}$ B

$$A_s = 0.29 \quad \text{Total} = 2(0.29) = 0.40 > 0.39$$

$$\phi M_n = 0.9 \left[60 (0.29) \left(14 - \frac{60 (0.29)}{2(0.65)(14)} \right) \right] = 12.5 \text{ k-ft/ft} \checkmark \text{ ok}$$

$$\phi V_n = \frac{0.75 (2) \sqrt{4000} (14)(14)}{1000} = 15.94 \text{ k/ft} \checkmark \text{ ok}$$

Use #4 @ 12" T $\frac{1}{2}$ B
 Transv. BARS
 - Use 5- #5 T $\frac{1}{2}$ B
 LONGIT BARS

8/26/16



S17 of 25

Lift Checks - Savaria V1504

Operational Loading:

LOAD $RZ = 472$ lbs in/out of plane of OF Studs

- Load is DTH \therefore Use $C_p = 1.0$ for this load.

Seismic

$A_p = 1.0$

$R_p = 2.5$

$S_{D5} = 1.341$

$z/h = 1/2$

$I = 1.0$

$F_{pmin} = 0.5 W_p \leftarrow \text{Controls}$

$F_{pmin} = 0.2 (1.341) (1.0) W_p$
 $= 0.40 W_p$

$F_p = \frac{0.4 (1.0) (1.341) (1.0)}{2.5} (1 + 2(1/2)) W_p = 0.43 W_p$

$F_{pmin} = \underline{\underline{0.5 W_p \leftarrow \text{Controls}}}$

W_p

Weight of Car = 500


Cap. = 750 lbs

$W_p = 500 + 0.4 (750) = \underline{\underline{800 \text{ lbs}}}$

$F_{Pact} = 0.5 (800) \times 0.7 = \underline{\underline{280 \text{ lbs}}}$

Total, divide to two Brackets.

Slab 25

Check Wall studs

DFL Nol + Better

 Since Seismic load $C_D = 1.6$

$$F_D' = 1704 \text{ psi} \times 1.6 = 2726 \text{ psi}$$

$$\text{Reaction} = 612 / 2 = \underline{306 \text{ lbs}}$$

$$S_{lim} = 9 \times 12 / 240 = 0.45''$$


$$I_x = \frac{(612)(9 \times 12)^3}{48(1800)(0.45'')} = \underline{19.83 \text{ in}^4}$$

$$S_r = \frac{(612)(9)}{2726} \times 12 = \underline{6.06 \text{ in}^3}$$

Use 4x6 + (2) 2x4 Per Savaria heavier recommendations

$$\Sigma I = 2(5.36) + 19.65 = \underline{30.4 \text{ in}^4}$$

$$\Sigma S = 2(3.06) + 11.23 = \underline{17.35 \text{ in}^3}$$



$$I_x = 5.36$$

$$S_x = 3.06$$

$$I_y = 19.65 \text{ in}^4$$

$$S_y = 11.23$$

$$I_x = 5.36$$

$$S_x = 3.06$$

Anchorage into 4x6

$$G = 0.50 \quad \text{DFL}$$

Try $3/8" \phi$ LAGS $W/3"$ total pen.

Table 11.2A (NDS)

$$W = 305 \text{ lbs/lin}$$

$$\text{Withdrawal pen} = 3" - 0.21875" = 2.78"$$

$$\text{Cap per Bolt} = (305 \times 2.78") \times 1.6 \times C_D = \underline{\underline{1357 \text{ lbs}}}$$

C_D
Seismic

In-plane Shear - (Table 11K NDS)

$$Z_{||} = 280 \text{ lbs (e 80 pen)}$$

$$Z'_{||} = 280 \times 1.6 = \underline{\underline{448 \text{ lbs}}}$$

Case 1 - Full pull-out

$$R = 612 \text{ lbs}$$

$$- 1 \ 3/8" \phi \text{ LAG} \quad W' = 1357 \text{ lbs} > 612 \checkmark$$

Case 2 - Operational pull-out only

$$W' = (305 \times 2.78") \times 1.0 = \underline{\underline{848 \text{ lbs} > 472 \checkmark \text{ ok}}}$$

C_D

Case 3 - Operational pull-out, Seismic in-plane

$$R = \sqrt{(472)^2 + (448)^2} = \underline{\underline{649 \text{ lbs}}} \quad \alpha = 73.5^\circ$$



$$\alpha = 90 - \text{ARCTAN} (140/472)$$

$$\alpha = 73.5^\circ$$

$$Z'_\alpha = \frac{(1357)(448)}{1357 \cos^2 73.5 + 448 \sin^2 73.5} = \underline{\underline{1166 \text{ lbs}}}$$

Use Min $1-3/8" \phi \times 34"$ LAG

AT EACH BRACKET MOUNT
LOCATION

Site Construction Details

The V1504 needs a wall that supports a minimum of 472 lb (2100 N) of pull out force at any bracket. The floor must be capable of supporting a load of 3200 lb (14.2 kN). See Figure 1. A wall with a combination of two columns of three 2x4's, or a concrete or brick wall is required.

Figure 2 details a sample wooden support wall configuration

Figure 1: Wall/Floor Loading






Figure 2: Sample Wooden Support Wall Configuration





2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - Greenheck MAU



- Height, H = 40.0 in
- Height to center of gravity, z = 20.0 in
- Width, W = 35.0 in
- Overturning Dimension, ω = 35.0 in
- # of anchors in tension, #_{T,ω} = 2
- x = 17.5 in
- x' = 17.5 in
- Length, L = 41.0 in
- Overturning Dimension, l = 41.0 in
- # of anchors in tension, #_{T,l} = 2
- y = 20.5 in
- y' = 20.5 in
- Weight, W_p = 300 lbs
- # of anchors in shear, #_v = 4
- Height of component with respect to grade, z = 15 ft
- Average roof height, h = 15 ft

Seismic

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

COMPONENT AMPLIFICATION FACTOR

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

a_p = 2.5

COMPONENT RESPONSE MODIFICATION FACTOR

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

R_p = 6.0

DESIGN SPECTRAL RESPONSE ACCELERATION

CBC Section 1613A.3.4 & CBC Equation 16A-39

S_{DS} = 1.341

COMPONENT IMPORTANCE FACTOR

ASCE Section 13.1.3

I_p = 1.00

ATTACHMENT FACTOR IN CONCRETE OR MASONRY

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

Ω factor = 1.0

SEISMIC DESIGN FORCE

ASCE Section 13.3.1 & ASCE Equation 13.3-1
 ASCE Section 13.3.1 & ASCE Equation 13.3-2
 ASCE Section 13.3.1 & ASCE Equation 13.3-3

$$F_p = 0.4 \cdot a_p \cdot S_{DS} \cdot W_p / (R_p / I_p) \cdot (1 + 2z/h) \quad F_p = 0.671 W_p$$

$$F_{p,max} = 1.6 \cdot S_{DS} \cdot I_p \cdot W_p \quad F_{p,max} = 2.146 W_p$$

$$F_{p,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p \quad F_{p,min} = 0.402 W_p$$

SEISMIC DESIGN FORCES (ASD)

ASCE Section 13.1.7 & 13.3.1
 ASCE Section 13.1.7 & 13.3.1

$$F_{p,ASD} = 0.7(F_{p,govern}) \quad F_{p,ASD} = 0.469 W_p$$

$$F_{pv,ASD} = 0.7(0.2 \cdot S_{DS} \cdot W_p) \quad F_{pv,ASD} = 0.188 W_p$$

DESIGN FORCES

$$F_{p,\Omega} = F_{p,ASD} \cdot W_p \cdot \Omega \text{ factor} = 141 \text{ lbs}$$

$$OTM = z \cdot F_{p,\Omega} = 2816 \text{ lb-in}$$

$$F_{pv,ASD} = 56 \text{ lbs}$$

$$DLRM = (0.6W_p - F_{pv,ASD}) \cdot x_{min} = 2164 \text{ lb-in}$$

$$T = \frac{OTM - DLRM}{\omega \cdot \#_{T,\omega}} + \frac{0.3 \cdot OTM}{l \cdot \#_{T,l}} \quad T = \boxed{20 \text{ lbs}}$$

$$V = \frac{F_{p,ASD,\Omega} \cdot (2 \cdot y_{max} / L)}{\#_v} \quad V = \boxed{35 \text{ lbs}}$$

(V is approximate when number of anchors exceeds 4)

Use (4) - 1/2"Ø Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Thin Substrates Condition)


T_{ALL} = 660 lbs
 V_{ALL} = 837 lbs
 UNITY CHECK = 0.07 **OK**

USE 5/16" φ
 LAGS INTO
 4x Blocking



S22 of 25

2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - Greenheck MAU



Height, H = 40.0 in
Width, W = 35.0 in
Overturning Dimension, ω = 35.0 in
of anchors in tension, $\#_{T,\omega}$ = 2
x = 17.5 in
x' = 17.5 in
Length, L = 41.0 in
Weight, W_p = 300 lbs
of anchors in shear, $\#_V$ = 4
Height of component with respect to grade, z = 15 ft

Wind

Wind design requirements for equipment are based on ASCE 7-10, Section 30.11

RISK CATEGORY (OC)

ASCE TABLE 1.5-1

RC = II

BASIC WIND SPEED (3 SECOND GUST)

ASCE Figure 26.5-1

V = 110 mph

EXPOSURE CATEGORY (EC)

ASCE SECTION 26.7

EC = B

VELOCITY PRESSURE EXPOSURE COEFFICIENT

ASCE Table 29.3.1

k_z = 0.70

TOPOGRAPHIC FACTOR

ASCE Section 26.8.2

k_{zt} = 1.0

WIND DIRECTIONALITY FACTOR

ASCE Table 26.6.1

k_d = 0.85

FORCE COEFFICIENT

ASCE Section 29.5.1

GC_r = 1.9

VELOCITY PRESSURE

ASCE Section 29.3.2

$q_z = 0.00256 * K_z * K_{zt} * K_d * V^2$

q_z = 18.4 psf

DESIGN WIND FORCE

ASCE Section 29.5.1

$P_{ASD} = 0.6 * (q_z * GC_r)$

P_{ASD} = 21.0 psf

DESIGN FORCES

$F_{ASD} = P_{ASD} * (H * L / 144) = 239$ lbs

OTM = $F_{ASD} * (H / 2) = 4790$ lb-in

DLRM = $(0.6 * W_p) * x_{min} = 3150$ lb-in

$T = \frac{OTM - DLRM}{\omega * \#_T}$

T = 1 lbs

$V = \frac{F_{ASD}}{\#_V}$

V = 60 lbs

Use (4) - 1/2"Ø Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Thin Substrates Condition)


$T_{ALL} = 880$ lbs

$V_{ALL} = 837$ lbs

UNITY CHECK = 0.07 OK

Still Small Anchor Same as previous page

S23 of 25



$$\begin{aligned}
 a_p &\sim 1.0 \\
 R_p &\sim 2.5 \\
 S_{os} &\sim 1.34 \\
 I_p &\sim 1.0 \\
 z/h &= 0.5
 \end{aligned}$$

$$F_p = \frac{0.4(1.0)(1.34)(1.0)}{2.5} (1 + 2(z/h)) W_p = \underline{0.43 W_p}$$

$$F_{pmin} = 0.3(1.34)(1.0) W_p \sim \underline{0.40 W_p}$$

$$F_p = 0.43(650) = 280 \text{ lbs (Factored)}$$

$$F_{P_{ASD}} = 0.7 \times 280 = \underline{\underline{196 \text{ lbs}}}$$

Top Reaction

$$R_t = 196 \text{ lbs} / 2 = \underline{\underline{98 \text{ lbs}}}$$

Attach to 3 studs/points

$$\therefore 98/3 = 32.7 \text{ lbs/Anchor}$$

- Very Small

Use #12 Wood screw

OR

Mas. Anchor


Base Reaction also = 98 lbs

To permit relatively easy cleaning of kitchen, lock front bottom casters, - provide Caster locks if not already provided.

Assume min 2-front casters $98/2 = 49 \text{ lbs}$ of shear at each wheel - very small - say ok with Caster locks. ✓

S24 of 25

 TRUE FOOD SERVICE EQUIPMENT, INC. 2001 East Terra Lane • O'Fallon, Missouri 63366-4434 • (636)240-2400 Fax (636)272-2408 • Toll Free (800)325-6152 • Intl Fax# (001)636-272-7546 Parts Dept. (800)424-TRUE • Parts Dept. Fax# (636)272-9471 • www.truefmg.com	Project Name: _____	A/A #
	Location: _____	S/S #
Model: T-72F	Item #: _____ Qty: _____	
T-Series: Reach-In Solid Swing Door -10°F Freezer		Model #: _____



T-72F

- ▶ True's solid door reach-ins are designed with enduring quality that protects your long term investment.
- ▶ Designed using the highest quality materials and components to provide the user with colder product temperatures, lower utility costs, exceptional food safety and the best value in today's food service marketplace.
- ▶ Extra large evaporator coil balanced with higher horsepower compressor and large condenser maintains -10°F (-23.3°C) cabinet temperatures. Ideally suited for both frozen foods and ice cream.
- ▶ Stainless steel solid doors and front. The finest stainless available with higher tensile strength for fewer dents and scratches.
- ▶ Adjustable, heavy duty PVC coated shelves.
- ▶ Positive seal self-closing doors. Lifetime guaranteed door hinges and torsion type closure system.
- ▶ Automatic defrost system time-initiated, temperature-terminated. Saves energy consumption and provides shortest possible defrost cycle.

Bottom mounted units feature:

- ▶ "No stoop" lower shelf.
- ▶ Storage on top of cabinet.
- ▶ Compressor performs in coolest, most grease free area of kitchen.
- ▶ Easily accessible condenser coil for cleaning.








ROUGH-IN DATA

Specifications subject to change without notice. Chart dimensions rounded up to the nearest 1/8" (millimeters rounded up to next whole number).

Model	Doors	Shelves	Cabinet Dimensions (inches) (mm)			HP	Voltage	Amps	NEMA Config.	Cord Length (total ft.) (total m)	Crated Weight (lbs.) (kg)
			L	D	H*						
T-72F	3	9	78 7/8 1985	29 1/2 750	78 3/8 1991	1 1 1/2	115/60/1 230-240/50/1	12.0 9.0	5-20P ▲	9 2.74	635 289

* Height does not include 5" (127 mm) for castors or 6" (153 mm) for optional legs. ▲ Plug type varies by country.

    	APPROVALS:	AVAILABLE AT:
2/15 Printed in U.S.A.		

Model: T-72F	T-Series: Reach-In Solid Swing Door -10°F Freezer	
------------------------	---	--

STANDARD FEATURES

DESIGN

- True's commitment to using the highest quality materials and oversized refrigeration systems provides the user with colder product temperatures, lower utility costs, exceptional food safety and the best value in today's food service marketplace.

REFRIGERATION SYSTEM

- Factory engineered, self-contained, capillary tube system using environmentally friendly (CFC free) R404A refrigerant.
- Extra large evaporator coil balanced with higher horsepower compressor and large condenser; maintains -10°F (-23.3°C). Ideally suited for both frozen foods and ice cream.
- Sealed, cast iron, self-lubricating evaporator fan motor(s) and larger fan blades give True reach-in's a more efficient low velocity, high volume airflow design. This unique design ensures faster temperature recovery and shorter run times in the busiest of food service environments.
- Bottom mounted condensing unit positioned for easy cleaning. Compressor runs in coolest and most grease free area of the kitchen. Allows for storage area on top of unit.
- Automatic defrost system time-initiated, temperature-terminated. Saves energy consumption and provides shortest possible defrost cycle.

CABINET CONSTRUCTION

- Exterior - Stainless steel front. Anodized quality aluminum ends, back and top.
- Interior - attractive, NSF approved, clear coated aluminum liner. Stainless steel floor with coved corners.

- Insulation - entire cabinet structure and solid doors are foamed-in-place using Ecomate. A high density, polyurethane insulation that has zero ozone depletion potential (ODP) and zero global warming potential (GWP).
- Welded, heavy duty steel frame rail, black powder coated for corrosion protection.
- Frame rail fitted with 4" (102 mm) diameter stem castors - locks provided on front set.

DOORS

- Stainless steel exterior with white aluminum liner to match cabinet interior. Doors extend full width of cabinet shell. Door locks standard.
- Lifetime guaranteed recessed door handles. Each door fitted with 12" (305 mm) long recessed handle that is foamed-in-place with a sheet metal interlock to ensure permanent attachment.
- Positive seal self-closing doors. Lifetime guaranteed door hinges and torsion type closure system.
- Magnetic door gaskets of one piece construction, removable without tools for ease of cleaning.

SHELVING

- Nine (9) adjustable, heavy duty PVC coated wire shelves 24 1/8" L x 22 3/8" D (613 mm x 569 mm). Four (4) chrome plated shelf clips included per shelf.
- Shelf support pilasters made of same material as cabinet interior; shelves are adjustable on 1/2" (13 mm) increments.

LIGHTING

- Incandescent interior lighting - safety shielded. Lights activated by rocker switch mounted above doors.

MODEL FEATURES

- Exterior temperature display.

- Evaporator is epoxy coated to eliminate the potential of corrosion.
- Rear airflow guards prevent product from blocking optimal airflow.
- NSF-7 compliant for open food product.

ELECTRICAL

- Unit completely pre-wired at factory and ready for final connection to a 115/60/1 phase, 20 amp dedicated outlet. Cord and plug set included.



OPTIONAL FEATURES/ACCESSORIES


Upcharge and lead times may apply.

- 230 - 240V / 50 Hz.
- 6" (153 mm) standard legs.
- 6" (153 mm) seismic/flanged legs.
- Alternate door hinging (factory installed).
- Novelty baskets.
- Additional shelves.
- Half door bun tray racks. Each holds up to eleven 18" L x 26" D (458 mm x 661 mm) sheet pans (sold separately) (airflow guards need to be removed).
- Full door bun tray racks. Each holds up to twenty-two 18" L x 26" D (458 mm x 661 mm) sheet pans (sold separately) (airflow guards need to be removed).

*CABINET INTERIOR

Beginning in October of 2014, True Manufacturing began the process of changing the standard interior finishes on select products. The interior liners of these units have changed from the traditional NSF-approved white aluminum to an NSF-approved clear coated aluminum that is silver in color. In addition, the traditional white PVC coated shelves have been switched to a gray PVC coating. There are no functional differences created by any of these changes, the difference is only in the appearance. The following product lines are affected by this change: T-Series, TUC, TWT, TSSU, TFP, TPP, TMC, TRCB. A sticker will be placed on the outside packaging so that units with this change can be identified in inventory.

PLAN VIEW



WARRANTY*
Three year warranty on all parts and labor and an additional 2 year warranty on compressor. (U.S.A. only)

METRIC DIMENSIONS ROUNDED UP TO THE NEAREST WHOLE MILLIMETER
SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE

*RESIDENTIAL APPLICATIONS: TRUE assumes no liability for parts or labor coverage for component failure or other damages resulting from installation in non-commercial or residential applications.

	Model	Elevation	Right	Plan	3D	Back
	T-72F	TFEY14E	TFEY01S	TFEY01P	TFEY143	

TRUE FOOD SERVICE EQUIPMENT